

EC-CERTIFICATE OF CONFORMITY

1415-CPD-45-(C-41/2012)

On the basis of Construction Products Directive – item (b) of article 14 (1) of Council's Directive No. 89/106/EEC of December 21, 1988 and article 4 of Directive No. 93/68/EEC of July 22, 1993 modifying the above Directive –, Section 41 of Hungarian Act LXXVIII of 1997 on formation and protection of the built environment as well as on the basis of the joint Ministerial Decree No. 3/2003. (I. 25.) BM-GKM-KvVM of Ministry of Interior, Ministry of Economy and Transport, and Ministry of Environment Protection and Water Management on detailed regulations of technical requirements, attestation of conformity, placing on the market and use of the construction products, we found that

MINERAL WOOL SLABS/BOARDS FOR THERMAL INSULATION OF BUILDING EQUIPMENT

(Products of product family are shown in the annex as page 2/2 of this certificate)

construction product
placed on market by

ROCKWOOL Hungary Szigetelőanyaggyártó és Kereskedelmi Kft.
Keszthelyi út 53., H-8300 Tapolca, Hungary

manufacturer
and produced in the factory plant

ROCKWOOL Hungary Szigetelőanyaggyártó és Kereskedelmi Kft.
Keszthelyi út 53., H-8300 Tapolca, Hungary

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory.

Furthermore, we found that ÉMI Non-profit Ltd. (Diószegi út 37., H-1113 Budapest, Hungary) – as notified body – has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

On the basis of the foregoing we certify hereby that the **product is in compliance** with all requirements set out in the annex ZA of standard no. EN 14303:2009.

This certificate remains valid until withdrawal as long as the conditions laid down in the harmonised technical specification in reference of the manufacturing conditions in the factory production control are not modified.

This certificate will authorise the manufacturer to apply CE-marking in a manner as set out in Annex of EN 14303:2009

This certificate consists of 2 pages!

Dated at Budapest, 30th November 2012





Pataki Erika
Head of Certification Office
TEI – Certification body
of ÉMI Non-profit Ltd.

1/2

EC-CERTIFICATE OF CONFORMITY

1415-CPD-45-(C-41/2012)

Annex

Product name	Thickness (mm)	Euroclass according to EN 13501-1	Thermal conductivity			Product marking according to EN 14303
			10 °C (λ_{10}) (Wm ⁻¹ K ⁻¹)	100 °C (λ_{100}) (Wm ⁻¹ K ⁻¹)	250 °C (λ_{250}) (Wm ⁻¹ K ⁻¹)	
Techrock 40 ALS	30-220	A1	0,037	0,054	0,106	MW-EN-14303-T4-ST(+)-250
Techrock 60 ALS	30-220	A1	0,035	0,049	0,085	MW-EN-14303-T4-ST(+)-250
Techrock 80 ALS	30-200	A1	0,034	0,045	0,075	MW-EN-14303-T4-ST(+)-250
Techrock 100 ALS	20-160	A1	0,034	0,046	0,075	MW-EN-14303-T4-ST(+)-250
Techrock 120 ALS	20-140	A1	0,035	0,046	0,069	MW-EN-14303-T4-ST(+)-250
Techrock 150 ALS	20-140	A1	0,036	0,050	0,073	MW-EN-14303-T4-ST(+)-250

Dated at Budapest, 30th November 2012



2/2

Patali E. László